

Texas Commission on Environmental Quality
Public Notification Form for Wastewater Discharges

Information about the Discharge

An unauthorized discharge or spill of wastewater has occurred from:

Wastewater Treatment Facility: ☒ Collection System: ☐

Facility Name: City of Hamilton

Person to contact for information: Albert Bennie (254) 977-3636

Location of spill(s): *Waste Water Treatment Plant*

Estimated date and time of spill(s): October 25th around 9:00 PM

Estimated volume of spill(s)(number of gallons): 100,000

Type of Spill (domestic, industrial, other): Domestic

Description of the area potentially affected, including down gradient and lateral distance from spill(s) site: Pecan Creek

Suspected cause of spill(s): Power Outage

List of actions taken including but, not limited to:

Notification of:

Appropriate local government officials: ☒ TCEQ Regional Office: ☒

Containment of spill: The spill has been contained to the WWTP area

Increased monitoring of water supply systems: The plant was monitored continuously until the incoming flow was back to normal levels.

Initiation or completion of cleanup activities: Discharge remaining after the plant was restored to power was vacuumed up and area was disinfected using powder chlorine.