

**2020 Annual Drinking Water Quality**

**Report Consumer Confidence Report**

**CITY OF HAMILTON**

**PWS ID Number 0970001 Phone Number: 254-386-  
8116**

## Special Notice

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.



## OUR DRINKING WATER IS REGULATED

This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

### Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

### En Español

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en Español, favor de llamar al telefono (254) 386 - 8116.

For more information regarding this report contact:

Name: Ryan Polster  
Phone: (254) 386-8116

**Where do we get our drinking water?**

Our drinking water is obtained from a SURFACE water source, PROCTOR LAKE in COMANCHE county.

Source Water Name	Type of Water	Report Status	Location
UPPER LEON RIVER MUNICIPAL WATER DISTRICT—TX0470015 UPPER	SW	ACTIVE	LAKE PROCTOR

**Information about Source Water Assessments**

The TCEQ has completed a Source Water Assessment for all drinking water systems that own their sources. The report describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The system(s) from which we purchase our water received the assessment report. For more information on source water assessments and protection efforts at our system, contact Gary Lacy at Upper Leon Municipal Water District or the report may be viewed at <http://ulrmwd.com/>. Additional information on source water assessments is available via the Source Water Assessment Viewer (URL: <https://www.tceq.texas.gov/gis/swaview> ) or through Drinking Water Watch (URL: <http://dww2.tceq.texas.gov/DWW/>).

**ALL drinking water may contain contaminants** ... When drinking water meets federal standards there may not be any health based benefits to purchasing bottled water or point of use devices. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants.

The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA’s Safe Drinking Water Hotline (1-800-426-4791).

**Secondary Constituents.** Many constituents (such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondaries are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

**About The Following Pages**

The pages that follow list all of the federally regulated or monitored contaminants which have been found in your drinking water. The U.S. EPA requires water systems to test for up to 97 contaminants.

**2020 Regulated Contaminants Detected**

**Coliform Bacteria**

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	0 positive monthly samples	0	0	0	N	Naturally present in the environment

**Turbidity**

Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

Year	Contaminant	Highest Single Measurement	Lowest Monthly % of Samples Meeting Limits	Turbidity Limits	Unit of Measure	Source of Contaminant
2020	Turbidity	0.43	95.70%	0.3	NTU	Soil Runoff

**TOC—Total Organic Compound**

Year	Contaminant (Unit of Measure)	Average Raw Water TOC	Average Treated Water	Average Monthly Compliance	Average Treated Water SUVA (L/mg-	Treatment Techniqu	Source of Contaminant
------	-------------------------------	-----------------------	-----------------------	----------------------------	-----------------------------------	--------------------	-----------------------

			<b>TOC</b>	<b>Ratio</b>	<b>m)</b>	<b>e Violation</b>	
2020	Total Organic Compound (ppm)	7.69	5.68	0.84	1.72	No	TOC is naturally present in the environment.

## 2020 Water Quality Test Results

Disinfection By-Products	Collection Date	Highest Level Or Average Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)*	2020	31	16.3 – 22.8	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

\* The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year\*

Total Trihalomethanes (TTHM)	2020	63	28.7 – 53.3	No goal for the Total	80	ppb	N	By-product of drinking water disinfection.
------------------------------	------	----	-------------	-----------------------	----	-----	---	--

\* The value in the highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year\*

Inorganic Contaminants	Collection Date	Highest Level Or Average Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Nitrate [measured as Nitrogen]	2020	0.29	0.29 - 0.29	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Nitrate [measured as Nitrogen]	2/18/15	0.03	0.03 - 0.03	1	1	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

## Regulated Contaminants - Supplied by Upper Leon Water Municipal Water District

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	7/15/2020	0.0021	0.0021 - 0.0021	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	7/15/2020	0.0947	0.0947 - 0.0947	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Cyanide	7/15/2020	<0.01	<0.01	200	200	mg/L	N	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories.
Fluoride	7/15/2020	0.17	0.17	4	4	mg/L	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum
Nitrate [measured as Nitrogen]	7/15/2020	0.08	0.08 - 0.08	10	10	mg/L	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Selenium	7/15/2020	0.0036	0.0036 - 0.0036	50	50	mg/L	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	3/21/2018	8.4	8.4 - 8.4	0	50	pCi/L*	N	Decay of natural and man-made deposits.

Combined Radium 226/228	5/29/2018	<1.0	<1.0 - <1.0	0	5	pCi/L	N	Erosion of natural deposits.
----------------------------	-----------	------	-------------	---	---	-------	---	------------------------------

\*EPA considers 50 pCi/L to be the level of concern for beta particles

## Lead and Copper

Lead and Copper	Date Sample d	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2020	1.3	1.3	0.048	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	9/27/2017	0	15	1	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

## Disinfectant Residual

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Chloramines	2020	1.91	0.51 – 4.00	4	4	mg/L	N	Water additive used to control microbes.

## Definitions and Abbreviations

**Definitions and Abbreviations:** The tables in this report contain scientific terms and measures, some of which may require explanation.

Action Level:	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Action Level Goal (ALG):	The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our system.
Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E.Coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL	million fibers per liter (a measure of asbestos)
mrem:	millirems per year (a measure of radiation absorbed by the body)
na:	not applicable.
NTU	nephelometric turbidity units (a measure of turbidity)
pCi/L	picocuries per liter (a measure of radioactivity)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppq:	parts per quadrillion, or picograms per liter (pg/L)
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
ppt:	parts per trillion, or nanograms per liter (ng/L)
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

